


# **ATF TWIN SPHERE – FLANGE END**





#### **MATERIALS**

Symbol	Parts Name	Material
1	Body (Outer Layer)	Special Synthetic Rubber
2	Body (Inner Layer)	Special Synthetic Rubber
3	Reinforcing Fabric	Nylon Fabric
4	Wire	Hard Steel Wire
5	Flange	Mild Steel (Galv'd)

**DIMENSIONS AND ALLOWABLE MOVEMENTS (inch)** 

Nominal Size		Neutral Length	Allowable Movements in Operation							
mm	inch	L	A.C.	A.E.	L.D.	A.D.				
32	1 <sup>1</sup> / <sub>4</sub> "	7	1	<sup>5</sup> / <sub>8</sub>	3/4	30⁰				
40	1 <sup>1</sup> / <sub>2</sub> "	7	1	<sup>5</sup> / <sub>8</sub>	3/4	30⁰				
50	2"	7	1	<sup>5</sup> / <sub>8</sub>	3/4	30⁰				
65	2 <sup>1</sup> / <sub>2</sub> "	7	1	<sup>5</sup> / <sub>8</sub>	3/4	30⁰				
80	3"	7	1	<sup>5</sup> / <sub>8</sub>	3/4	30⁰				
100	4"	9	1 <sup>1</sup> / <sub>4</sub>	3/4	1	30⁰				
125	5"	9	1 <sup>1</sup> / <sub>4</sub>	3/4	1	30⁰				
150	6"	9	1 <sup>1</sup> / <sub>4</sub>	3/4	1	30⁰				
200	8"	13	11/2	1	1 1/ <sub>4</sub>	30⁰				
250	10"	13	11/2	1	1 1/ <sub>4</sub>	30⁰				
300	12"	13	11/2	1	1 1/4	30º				

A.C.=Axial Compression A.E.=Axial Elongation L.D.=Lateral Deflection A.M.=Angular Deflection

## **OPERATING CONDITIONS**

- ♦ Operating Pressure: 232 psi
- ♦ Operating Temperature: 14º to 176ºF
- ♦ Vacuum Rating: 25" / Hg
- Applicable Fluids: Water, Warm Water, Sea Water, Air & Weak Acid
- → Flange Standard: DIN, ANSI, JIS & BS

#### **Operating Temperature against Operating Pressure**

Operating Temperature <sup>o</sup> F	Ambient	122	140	158	176
Maximum Operating Pressure (psi)	232	180	145	110	95

## **NOTES**

- Higher temperatures affect movement and pressure. As temperature increases, rated values must be reduced accordingly.
- Pressures shown are recommended "operating", test pressure is 1.5 times "operating".
- Vacuum rating is based on neutral installed length without external load. Products shall not be installed "elongated" on vacuum applications.
- Expansion joints may operate in pipelines or equipments carrying fluids at evaluated temperatures and pressures. Normal precautions shall be taken to make sure these parts are installed correctly and inspected regularly. Precautions shall be taken to protect personnel in the event of leakage or splash.
- For other kinds of applicable fluids, except the above, to which the rubber joint becomes applicable, please kindly consult your supplier or manufacturer.

